

Long-term Performance and O&M Costs for the Marchand Passive Treatment System

Bob Hedin

Hedin Environmental
Iron Oxide Recovery

Elements of a Successful Treatment System

- Effluent quality meets expectations
- Routine operational needs are satisfied
- Major maintenance needs are satisfied
- The total cost of treatment is affordable

Marchand Passive Treatment System

- Pittsburgh coal seam deep mine abandoned in 1940's
- Discharge into Sewickley Creek (Youghiogheny River)
 - 1,500 – 2,500 gpm; high metals
- Since 1990s, alkaline Fe chemistry
 - pH 6.3, Fe 60-80 mg/L, Mn 1 mg/L, Al <1 mg/L,
- Passive system installed in 2005/06 by Sewickley Creek Watershed Association
- \$1,250,000 for design, permitting, construction



© 2012 Google

Google earth

Imagery Date: 7/2/2010 1993

40°14'55.40" N 79°45'56.89" W elev 767 ft

Eye alt 3072 ft






Effluent quality meets expectations?

Marchand System Average Performance, Nov '06 – May '12

	Flow	pH	Alk	Fe	Mn	Al	SO ₄
	gpm		mg/L	mg/L	mg/L	mg/L	mg/L
Influent	1,887	6.3	334	72.5	1.2	<0.2	1,137
Effluent	na	7.8	215	1.0	0.5	<0.2	1,166



Routine Operation

- Inspections every 2-3 months by volunteers
- Sampling when funding allows
- Trough and pipe cleanouts





© 2012 Google

Google earth

Imagery Date: 7/2/2010 1993

40°14'55.40" N 79°45'56.89" W elev 767 ft

Eye alt 3072 ft


Routine Operation

- Inspections every 2-3 months by volunteers
- Sampling when funding allows
- Trough and pipe cleanouts
- Approximately 75 man-hrs/yr

Major Maintenance

2008	Berm modifications in wetland and trough improvements (\$6,000)
2010	Wetland discharge channel repairs , wetland bank reinforcement, pipe cleanout (\$10,000)
2011	Pipe cleanout (\$2,000)
2012	Pipe removal and replacement with troughs (\$15,000)
2012	Sludge removal from Ponds A, B, and C (\$119,000)

Effluent, Nov 2006 - Apr 2012



Sludge Removal

- June 18 – 29, 2012
- Coordinated with pipe replacement project
- Cleaned out first three ponds





© 2012 Google

Google earth

Imagery Date: 7/2/2010 1993

40°14'55.40" N 79°45'56.89" W elev 767 ft

Eye alt 3072 ft






























Concentrations of Fe at the wetland effluent The project began on June 18. Water was bypassed into Pond B on June 18, into Pond C on June 22, and into Pond D on June 25. The project finished on June 29. The last two data points were collected with the system was again operating as designed. Sludge recovery did not degrade the final effluent

Sludge Removal


- June 18 – 29, 2012
- Coordinated with pipe replacement project
- Cleaned out first three ponds
- Cost
 - Materials \$66,000
 - Machinery \$20,000
 - Labor \$33,000
 - Total \$119,000 (Geotubes, \$63,000)
- Supported in part by WPCAMR Growing Greener Grant

What Happens to the Sludge?

- Passively dry to 45% solids
- Sell as high purity iron oxide solid
- Landfill



Sales 2001-2012
3,420 tons



■ pigment
■ reactivity

Composition of Treatment Solids

	Sludge Composition (dry weight)							
	Si	Al	Fe	Mn	Mg	Ca	S	C
Treatment Type and AMD Chemistry	%	%	%	%	%	%	%	%
Lime: pH 3, Fe 70, Al 3	1.3	1.6	10.0	1.1	4.8	21.0	1.7	6.5
NaOH: pH 3, Fe 40, Al 20, Mn 20	3.4	6.6	4.1	8.9	14.7	2.6	na	na
H₂O₂: pH 7, Fe 15, Al <1, Mn <1	1.5	0.1	51.3	0.1	0.0	1.3	0.1	na
Aeration: pH 7, Fe 80, Al <1, Mn 2	1.6	0.2	47.6	0.1	1.7	3.1	na	na
Passive: pH 6, Fe 75, Al <1, Mn 2	2.3	0.2	54.3	0.0	0.0	0.3	0.2	1.4
Passive: pH 5, Fe 115, Al <1, Mn 14	0.3	0.0	57.3	0.0	0.0	0.0	na	na
Passive: pH 4, Fe 40, Al 3, Mn 1	0.7	0.1	54.0	0.0	0.0	0.0	1.8	na
Reference, Goethite ,FeOOH			62.9					
Reference, Calcite, CaCO ₃						40.0		12.8
Reference, Gypsum, CaSO ₄ 2H ₂ O						23.3	18.6	

Financial Analysis (sludge disposal)

	Cost	Present Value*	\$/Fe(ton)	\$/1000 gal
Construction	\$1,250,000	\$1,250,000	\$127	\$0.032
Operations	\$2,000/yr	\$47,000	\$12	\$0.003
Maintenance	\$5,000/yr	\$117,000	\$12	\$0.003
Sludge recovery	\$41,000/yr	\$967,000	\$98	\$0.024
Sludge sale	(\$4,000)	(\$92,000)	(\$9)	(\$0.002)
Total, with Sludge Sale		\$2,290,000	\$232	\$0.058
Sludge disposal	\$44,000/yr	\$1,024,000	\$104	\$0.026
Total with disposal		\$3,405,000	\$345	\$0.086

*PV Assumptions: 40 years, 0.029% net return on investment

Financial Analysis (sludge disposal)

	Cost	Present Value*	\$/Fe(ton)	\$/1000 gal
Construction	\$1,250,000	\$1,250,000	\$127	\$0.032
Operations	\$2,000/yr	\$47,000	\$12	\$0.003
Maintenance	\$5,000/yr	\$117,000	\$12	\$0.003
Sludge recovery	\$41,000/yr	\$967,000	\$98	\$0.024
Sludge sale	(\$4,000)	(\$92,000)	(\$9)	(\$0.002)
Total, with Sludge Sale		\$2,290,000	\$232	\$0.058
Sludge disposal	\$44,000/yr	\$1,024,000	\$104	\$0.026
Total with disposal		\$3,405,000	\$345	\$0.086


*PV Assumptions: 40 years, 0.029% net return on investment

These unit costs are 1/3 – 1/2 the unit costs of lime treatment plants.

Elements of a Successful Treatment System

Marchand Assessment

- Effluent quality meets expectations
- Routine operational needs are satisfied
- Major maintenance needs are satisfied
- The total cost of treatment is affordable



Comments or Questions?



Removed slides

How do these costs compare?

- Marchand: total cost is \$0.062 / 1000 gallons
- LTV Lime Treatment Plants
 - 7,000 gpm, Fe discharges
 - \$1,000,000/yr
 - \$0.160 / 1000 gallons for operational costs
- Lancashire
 - 6,000 gpm, Fe discharge
 - \$13,000,000 construction
 - \$300,000/yr (???)
 - \$0.159 / 1000 gallons for construction and operation

